

January 24, 2017

David Spacone  
City School District of the City of Niagara Falls  
Director of Facilities  
630 – 66<sup>th</sup> Street  
Niagara Falls, NY 14304

**Re: Investigation and Sampling of Drinking Water for Lead Concentrations**

Dear Mr. Spacone:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the City School District of the City of Niagara Falls, including:

- Niagara Falls High School, 4455 Porter Road, Niagara Falls, New York

This report is prepared to assist the District in complying with the requirements of New York State (NYS) regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on 10/8/2016. The Protocol for the Investigation followed the requirements of NYS regulations as well as United States Environmental Protection Agency (USEPA) Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 36 sources of potable water in Niagara Falls High School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to City School District of the City of Niagara Falls.

Sincerely,  
Stohl Environmental, LLC.



William K. Sisco  
Senior Project Manager

**Investigation and Sampling  
Of Sources of Potable Water  
For Lead Concentrations**

**Prepared for:**

**David Spacone  
City School District of the City of Niagara Falls  
Director of Facilities  
630 – 66<sup>th</sup> Street  
Niagara Falls, NY 14304**

**Prepared by:**



**ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES**

**4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219**

**☎ (716) 312-0070 📠 (716) 312-8092**

**[www.stohlenvironmental.com](http://www.stohlenvironmental.com)**

**Conditions as of October 8, 2016**



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
www.stohlenvironmental.com

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## Summary Tabulation

### Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.1 Sampling Protocol and Summary of Results:

Stohl Environmental was retained by City School District of the City of Niagara Falls to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Niagara Falls High School, 4455 Porter Road, Niagara Falls, New York

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from all outlets in Niagara Falls High School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

### Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **‘3Ts for Reducing Lead in Drinking Water in Schools’**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of eight (8) hours, but not more than 18 hours before sample collection.
- **Service Connection Sampling:** Samples were collected at the service connection as follows:
  - **Service Connection Sample:** As detailed in EPA guidance documents, this sample is not a first-draw sample. The cold water tap closest to the service connection was opened, and the sample was collected immediately after a change in water temperature was detected, or after 30 seconds.
  - **Water Main Sample:** This sample was collected at the same location as the Service Connection sample; however, it was collected after water was allowed to run an additional three (3) minutes after the temperature change, but not more than three (3) minutes and thirty (30) seconds.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.2 Executive Summary of Sampling and Analysis:

### Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Niagara Falls High School	10/8/2016	379	343	36	0	0

\*\* Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

### Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples and Confirmatory Samples				
Sample #	Sample Type	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
111.11-174	First Draw	Copy Room	Sink	15.7
111.11-189	First Draw	Room 131 (hood, east side of room)	Sink	59.2
111.11-1	First Draw	Room 141 (hood, north side of room)	Sink	54.1
111.11-29	First Draw	Room 111 (hood)	Sink	106
111.11-35	First Draw	Room 111 (back room)	Sink	49.0
111.11-44	First Draw	Room 121	Sink	293
111.11-51	First Draw	Exterior of Room 115	Hose Bib	16.5
111.11-52	First Draw	Exterior of Room 117	Hose Bib	23.1
111.11-53	First Draw	Exterior of Room 116	Hose Bib	17.0
111.11-54	First Draw	Exterior of Room 122	Hose Bib	140
111.11-55	First Draw	Exterior of Room 126	Hose Bib	47.9
111.11-56	First Draw	Exterior of Room 127	Hose Bib	278
111.11-57	First Draw	Exterior of Room 121	Hose Bib	109
111.11-58	First Draw	Exterior of Room 137	Hose Bib	205
111.11-59	First Draw	Exterior of Room 136	Hose Bib	34.4
111.11-60	First Draw	Exterior of Door 8	Hose Bib	221
111.11-61	First Draw	Exterior of Room 146	Hose Bib	100
111.11-62	First Draw	Exterior of Room 147	Hose Bib	318

**A MEMBER OF THE STOHL GROUP OF COMPANIES**

Sample #	Sample Type	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
111.11-63	First Draw	Exterior of Door	Hose Bib	50.7
111.11-65	Water Main Flush	Water Main Flush	Hot Box	63.3
111.11-229	First Draw	Room 211 (hood)	Sink	98.5
111.11-245	First Draw	Room 221 (hood)	Sink	29.5
111.11-253	First Draw	Room 260	Sink	36.4
111.11-267	First Draw	Room 231 (hood)	Sink	87.6
111.11-273	First Draw	Room 231 (back room)	Sink	16.0
111.11-329	First Draw	Room 331 (hood)	Sink	46.5
111.11-340	First Draw	Faculty Women's Restroom near Room 320	Sink	18.6
111.11-341	First Draw	Room 320 (hood)	Sink	31.5
111.11-354	First Draw	Room 311 Storage	Sink	37.2
111.11-359	First Draw	Room 321 (left side window sink)	Sink	291
111.11-362	First Draw	Room 321 (center left door sink)	Sink	16.8
111.11-363	First Draw	Room 321 (hood)	Sink	16.7
111.11-410	First Draw	Room 441 (hood)	Sink	71.2
111.11-431	First Draw	Room 440 (hood)	Sink	115
111.11-435	First Draw	Room 431, prep room sink	Sink	152
111.11-455	First Draw	Room 421 (hood)	Sink	45.6

**1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:**

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than one (1) business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than ten (10) business days after the school received the laboratory report.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.4 Laboratory Analytical Reports by Building



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 11 rows of data for Lead analysis, all showing results <5.00.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.





Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 22 rows of lead analysis data for various sample IDs (188070-012 to 188070-022) with results consistently <5.00.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Stohl Environmental, LLC (4507)  
Address: 4169 Allendale Parkway  
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water  
Received: 10/12/16  
Reported: 01/11/17

Attn:  
Project: Niagara Falls High School  
Location: 4455 Portor Rd  
Number:

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
188070-023	111.11-122	Café A MBR S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/03/17	SA
188070-024	111.11-123	Café MBR S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/03/17	SA
188070-025	111.11-124	Café WBR S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/03/17	SA
188070-026	111.11-125	Café WBR S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/03/17	SA
188070-027	111.11-126	Fac Dining WBR S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/03/17	SA
188070-028	111.11-127	Fac Dining MBR S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/03/17	SA
188070-029	111.11-128	Kitchen S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/03/17	SA
188070-030	111.11-129	Kitchen S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/03/17	SA
188070-031	111.11-130	Kitchen S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/03/17	SA
188070-032	111.11-131	Kitchen S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/03/17	SA
188070-033	111.11-132	Kitchen S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/03/17	SA

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 16 rows of data for various sample IDs (188070-034 to 188070-044) and their corresponding lead analysis results.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for 'Metals Analysis' (Lead) across various sample IDs and locations.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for 'Metals Analysis' (Lead) across various sample IDs (188070-056 to 188070-066).

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 188070-067 through 188070-077 with corresponding analysis results for Lead.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for Lead analysis at various locations (CO WBR DF, Women Faculty S, Men Faculty S, CO MBR DF, MBR S, 131 S).

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 18 rows of lead analysis data for samples 188070-089 to 188070-099.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.





Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 10 rows of lead analysis data for various sample IDs (188070-100 to 188070-110).

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 15 rows of data for Lead analysis across various sample IDs (188070-111 to 188070-121).

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for Metals Analysis (Lead) across various sample IDs (188070-122 to 188070-132).

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 188070-133 through 188070-143, all for Lead analysis.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 188070-144 through 188070-154, all for Lead analysis.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 188070-155 through 188070-165, all for Lead analysis.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 18 rows of data for Lead analysis across various sample IDs (188070-166 to 188070-176).

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for Lead analysis at various locations (256E S, 256D S, 256C S, 255 S, Staff Lounge S, Staff Workroom S, CO MBR DF).

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.





Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include various sample IDs (188070-188 to 188070-198) and their corresponding analysis results for Lead.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include various sample IDs (188070-199 to 188070-208) and their corresponding analysis results for Lead.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 18 rows of lead analysis data for samples 188070-209 through 188070-219.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 188070-220 through 188070-230, all showing Lead analysis results.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for Lead analysis across various sample IDs (188070-231 to 188070-241).

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 188070-242 through 188070-252, all showing Lead analysis results.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

# Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117  
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

**Customer:** Stohl Environmental, LLC (4507)  
**Address:** 4169 Allendale Parkway  
Blasdell, NY 14219

<b>Order #:</b>	188070
-----------------	--------

**Matrix** Drinking Water  
**Received** 10/12/16  
**Reported** 01/11/17

**Attn:**  
**Project:** Niagara Falls High School  
**Location:** 4455 Portor Rd  
**Number:**

**PO Number:**

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
188070-253	111.11-300	341 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/07/17	MBH
188070-254	111.11-301	341 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/07/17	MBH
188070-255	111.11-302	341 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/07/17	MBH
188070-256	111.11-303	341 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/07/17	MBH
188070-257	111.11-304	341 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/07/17	MBH
188070-258	111.11-305	341 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/07/17	MBH
188070-259	111.11-306	341 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/07/17	MBH
188070-260	111.11-307	341 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/07/17	MBH
188070-261	111.11-308	341 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/06/17	MBH
188070-262	111.11-309	Hall Near 342 DF					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/06/17	MBH
188070-263	111.11-310	Hall Near 342 DF					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	01/06/17	MBH

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for 'Metals Analysis' (Lead) across various sample IDs and locations.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.





Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for Lead analysis across various sample IDs (188070-275 to 188070-285).

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for Lead analysis in various locations like Men's Bathroom, Faculty Men's, Hall, and Women's.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 188070-297 through 188070-307 with corresponding analysis results for Lead.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 188070-308 through 188070-318 with corresponding analysis results for Lead.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for Lead analysis in various rooms (Water Fountain DF, Room 441 S, Men's Room S).

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for Lead analysis across various sample IDs (188070-330 to 188070-340).

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include various sample IDs (188070-341 to 188070-351) and their corresponding analysis results for Lead.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for Metals Analysis (Lead) across various sample IDs and locations.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.





Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for Lead analysis in various rooms (Men's Room S, Men's Faculty Restroom S, Room 420 S, Room 421 S).

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 188070

Matrix: Drinking Water
Received: 10/12/16
Reported: 01/11/17

Attn:
Project: Niagara Falls High School
Location: 4455 Portor Rd
Number:

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for Lead analysis across different sample IDs (188070-374 to 188070-378).

188070-01/11/17 04:31 PM

Abisola O Kasali

Reviewed By: Abisola Kasali
Metals Supervisor

EPA Regulatory Limits

Table with 3 columns: Parameter, Reg. Limit, Unit. Row for Lead with Reg. Limit 15.0 and Unit µg/L.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



**Analysis Report**

**Schneider Laboratories Global, Inc**

2512 W. Cary Street • Richmond, Virginia • 23220-5117  
 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

**Customer:** Stohl Environmental, LLC (4507)  
**Address:** 4169 Allendale Parkway  
 Blasdell, NY 14219

**Order #:** 188070

**Matrix** Drinking Water  
**Received** 10/12/16  
**Reported** 01/11/17

**Attn:**  
**Project:** Niagara Falls High School  
**Location:** 4455 Portor Rd  
**Number:**

**PO Number:**

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					

**Certifications**

Parameter	Method	Matrix	CA	CT	FL	ND	NJ	NY	RI	VA
Lead	EPA 200.9 Rev 2.2	Drinking Water	X	X	X	X	X	X	X	X

**Key**

State	Regulatory Agency - Lab ID	Certificate Number
CA	CA ELAP	2078
CT	CT DPH	PH-0118
FL	FL ELAP	E87828
ND	North Dakota	R-221
NJ	NJDEP	NLC160001
NY	NYELAP-11413	55043
RI	RIDOH	LAO00084
VA	Virginia DCLS/DEQ - 460135	8615

'X' indicates that the analyte is accredited.

If your state is not listed above, call laboratory for accreditation/certification information.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 190148

Matrix: Drinking Water
Received: 10/28/16
Reported: 11/02/16

Attn:
Project: Niagara Falls High School
Location: 4455 Porter Rd. Niagara Falls
Number: 2016L-111

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Row 1: 190148-001, 111.11-235, 214 BR, EPA 200.9 Rev 2.2, <5.00, 5.00, µg/L, 11/01/16, SA.

190148-11/02/16 03:48 PM

Abisola O Kasali

Reviewed By: Abisola Kasali
Metals Supervisor

EPA Regulatory Limits

Table with columns: Parameter, Reg. Limit, Unit. Row 1: Lead, 15.0, µg/L

Certifications

Table with columns: Parameter, Method, Matrix, CA, CT, FL, NJ, NY, RI, VA. Row 1: Lead, EPA 200.9 Rev 2.2, Drinking Water, X, X, X, X, X, X, X

Key

Table with columns: State, Regulatory Agency - Lab ID, Certificate Number. Rows for CA, CT, FL, NJ, NY, RI, VA.

'X' indicates that the analyte is accredited.

If your state is not listed above, call laboratory for accreditation/certification information.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued September 22, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2003) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

**Metals I**

Lead, Total

EPA 200.9 Rev. 2.2



Serial No.: 55043

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2003) for the category  
ENVIRONMENTAL ANALYSES NON POTABLE WATER  
All approved analytes are listed below:*

**Metals I**

Lead, Total  
EPA 200.7 Rev. 4.4  
EPA 6010C  
EPA 7000B  
EPA 200.9 Rev. 2.2

**Sample Preparation Methods**

EPA 3010A  
EPA 3005A  
EPA 3020A



Department  
of Health

Serial No.: 54667

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2003) for the category  
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE  
All approved analytes are listed below:*

**Characteristic Testing**

**Polychlorinated Biphenyls**

TCLP EPA 1311

PCB-1268 EPA 8082A

**Metals I**

**Sample Preparation Methods**

Barium, Total EPA 6010C

EPA 3010A

Cadmium, Total EPA 6010C

EPA 3050B

Chromium, Total EPA 6010C

EPA 3550C

Lead, Total EPA 6010C

EPA 3031

EPA 7000B

Nickel, Total EPA 6010C

Silver, Total EPA 6010C

**Metals II**

Antimony, Total EPA 6010C

Arsenic, Total EPA 6010C

Chromium VI EPA 7196A

Mercury, Total EPA 7471B

Selenium, Total EPA 6010C

**Polychlorinated Biphenyls**

PCB-1016 EPA 8082A

PCB-1221 EPA 8082A

PCB-1232 EPA 8082A

PCB-1242 EPA 8082A

PCB-1248 EPA 8082A

PCB-1254 EPA 8082A

PCB-1260 EPA 8082A

PCB-1262 EPA 8082A

NEW  
YORK  
STATE

Department  
of Health

Serial No.: 54668

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.





NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory for the category  
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE  
All approved subcategories and/or analytes are listed below:*

**Miscellaneous**

Asbestos in Friable Material	EPA 600/M4/82/020
Asbestos in Non-Friable Material-PLM	Item 198.6 of Manual (NOB by PLM)
Lead in Dust Wipes	EPA 7000B
Lead in Paint	EPA 7000B

**Sample Preparation Methods**

EPA 3050B



Serial No.: 54669

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory for the category  
ENVIRONMENTAL ANALYSES AIR AND EMISSIONS  
All approved subcategories and/or analytes are listed below:*

**Metals I**

Lead, Total                      NIOSH 7082  
    40 CFR PART 50 1984 APP G

**Miscellaneous**

Fibers                              NIOSH 7400 A RULES



**Serial No.: 54670**

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.6 Chains of Custody



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
4169 ALLENDALE PKWY., BUFFALO, NEW YORK 14219  
(716) 312-0070 (716) 312-8892  
www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.11

Client: Niagara Falls CSD

Contact: Dave Spacone

Building: Niagara Falls High School

Location: 4455 Porter Rd

**LEAD**  
Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-100	WBR	S	11:10	0		
111.11-101	WBR	S	11:11	0		
111.11-102	WBR	S	11:11	0		
111.11-103	WBR	S	11:12	0		
111.11-104	WBR	S	11:12	0		
111.11-105	Concession	S	11:13	0		
111.11-106	MBR	S	11:19	0		
111.11-107	MBR	S	11:19	0		
111.11-108	MBR	S	11:20	0		
111.11-109	MBR	S	11:21	0		
111.11-110	192	S	11:26	0		
111.11-111	192 BR	S	11:27	0		
111.11-112	191	S	11:28	0		
111.11-113	191 BR	S	11:28	0		
111.11-114	Cafe D	DF	11:32	NWCA8FBL-002		
111.11-115	Cafe D	DF	11:33	0		
111.11-116	Cafe D MBR	S	11:34	0		
111.11-117	Cafe D MBR	S	11:34	0		

188070 S 378

V:\188\188070  
fghraizi 10/12/2016 12:35:00 PM  
Federal Express 77743 723669

**Notes:**

Please e-mail lab results to labs@stohlenv.com  If checked, also e-mail results to: \_\_\_\_\_

Sampled By: [Signature] Print Name Stohl Env: Michael Irwin Date: 10/8/2016

Relinquished By: [Signature] Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-0070 ■ (716) 312-8092  
 www.stohlenvironmental.com

STOHL Job # 2016L-111.11

Client: Niagara Falls CSD

Contact: Dave Spacone

Building: Niagara Falls High School

Location: 4455 Porter Rd

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-118	Cafe D WBR	S	11:35	0		
111.11-119	Cafe D WBR	S	11:35	0		
111.11-120	Cafe A	DF	11:36	NWCA8FBL-002		
111.11-121	Cafe A	DF	11:36	0		
111.11-122	Cafe A MBR	S	11:37	0		
111.11-123	Cafe MBR	S	11:37	0		
111.11-124	Cafe WBR	S	11:38	0		
111.11-125	Cafe WBR	S	11:38	0		
111.11-126	Fac Dining WBR	S	11:40	0		
111.11-127	Fac Dining MBR	S	11:41	0		
111.11-128	Kitchen	S	11:43	0		
111.11-129	Kitchen	S	11:43	0		
111.11-130	Kitchen	S	11:45	0		
111.11-131	Kitchen	S	11:46	0		
111.11-132	Kitchen	S	11:46	0		
111.11-133	Kitchen	S	11:47	0		
111.11-134	Kitchen	S	11:48	0		
111.11-135	Kitchen	S	11:49	0		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By: 0 [Signature] Print Name Stohl Env: Michael Irwin Date: 10/8/2016

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider  
 STOHL Job # 2016L-111.11

Client: Niagara Falls CSD Contact: Dave Spacone  
 Building: Niagara Falls High School Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X Turnaround 5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-136	Kitchen	S	11:49	0		
111.11-137	Kitchen	Sprayer	11:50	0		
111.11-138	Kitchen	S	11:51	0		
111.11-139	Kitchen	S	11:52	0		
111.11-140	Kitchen	S	11:53	0		
111.11-141	Kitchen	S	11:54	0		
111.11-142	Kitchen WBR	S	11:55	0		
111.11-143	Kitchen MBR	S	11:56	0		
111.11-144	Cafe B	DF	12:05	NWCA8FBL-002		
111.11-145	Cafe B	DF	12:06	0		
111.11-146	Cafe B WBR	S	12:07	0		
111.11-147	Cafe B WBR	S	12:08	0		
111.11-148	Cafe B MBR	S	12:09	0		
111.11-149	Cafe B MBR	S	12:10	0		
111.11-150	Cafe C	DF	12:16	NWCA8FBL-002		
111.11-151	Cafe C	DF	12:16	0		
111.11-152	Cafe C WBR	S	12:18	0		
111.11-153	Cafe C MBR	S	12:19	0		

**Notes:**

Please e-mail lab results to labs@stohlenv.com

Sampled By: [Signature] Print Name Stohl Env: Michael Irwin Date: 10/8/2016

Relinquished By: [Signature] Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-0070 ■ (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.11

Client: Niagara Falls CSD

Contact: Dave Spacone

Building: Niagara Falls High School

Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-154	Custodial WBR	S	12:22	0		
111.11-155	Custodial MBR	S	12:23	0		
111.11-156	CO Custodial	DF	12:24	NWCA8FBL-002		
111.11-157	CO Custodial	DF	12:24	0		
111.11-158	Concession	S	12:28	0		
111.11-159	CO MLR	DF	12:32	NWCA8FBL-002		
111.11-160	CO MLR	DF	12:32	0		
111.11-161	MLR	S	12:33	0		
111.11-162	MLR	S	12:33	0		
111.11-163	MLR	S	12:34	0		
111.11-164	M Gym Office	S	12:35	0		
111.11-165	W Gym Office	S	12:36	0		
111.11-166	CO WLR	DF	12:37	NWCA8FBL-002		
111.11-167	CO WLR	DF	12:37	0		
111.11-168	WLR	S	12:37	0		
111.11-169	WLR	S	12:38	0		
111.11-170	WLR	S	12:38	0		
111.11-171	Health Office	S	12:41	0		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By:  Print Name Stohl Env: Michael Irwin Date: 10/8/2016

Relinquished By:  Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY, BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8992  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider  
 STOHL Job # 2016L-111.11

Client: Niagara Falls CSD Contact: Dave Spacone  
 Building: Niagara Falls High School Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X Turnaround 5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-172	Health Office	S	12:42	0		
111.11-173	Health Office	S	12:43	0		
111.11-174	Copy RM	S	12:44	0		
111.11-175	WBR	S	12:46	0		
111.11-176	WBR	S	12:46	0		
111.11-177	CO WBR	DF	12:47	NWCA8FBL-002		
111.11-178	Women Faculty	S	12:48	0		
111.11-179	Men Faculty	S	12:50	0		
111.11-180	CO MBR	DF	12:50	NWCA8FBL-002		
111.11-181	CO MBR	DF	12:50	0		
111.11-182	MBR	S	12:50	0		
111.11-183	MBR	S	12:51	0		
111.11-184	MBR	S	12:51	0		
111.11-185	131	S	12:53	0		
111.11-186	131	S	12:53	0		
111.11-187	131	S	12:54	0		
111.11-188	131	S	12:55	0		
111.11-189	131	S	12:56	0		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By: [Signature] Print Name Stohl Env: Michael Irwin Date: 10/8/2016  
 Relinquished By: [Signature] Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016  
 Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_





# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-0070 ■ (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider  
 STOHL Job # 2016L-111.11

Client: Niagara Falls CSD Contact: Dave Spacone  
 Building: Niagara Falls High School Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-190	131	S	12:57	0		
111.11-191	131	S	12:57	0		
111.11-192	131	S	12:58	0		
111.11-193	131	S	12:58	0		
111.11-194	131	S	12:59	0		
111.11-195	131	S	12:59	0		
111.11-196	141	S	1:00	0		
111.11-197	141	S	1:00	0		
111.11-198	141	S	1:01	0		
111.11-199	141	S	1:01	0		
111.11-1	141	S	1:02	0		
111.11-2	141	S	1:02	0		
111.11-3	141	S	1:03	0		
111.11-4	141	S	1:03	0		
111.11-5	141	S	1:04	0		
111.11-6	141	S	1:05	0		
111.11-7	141	S	1:06	0		
111.11-8	Office 2 BR	S	1:10	0		

**Notes:**

Please e-mail lab results to labs@stohlenv.com

Sampled By: *Michael Irwin* Print Name Stohl Env: Michael Irwin Date: 10/8/2016

Relinquished By: *Eric Henderson Jr.* Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.11

Client: Niagara Falls CSD

Contact: Dave Spacone

Building: Niagara Falls High School

Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-9	Senior Lounge	S	1:13	0		
111.11-10	Senior Lounge BR	S	1:14	0		
111.11-11	101 Art	S	1:16	0		
111.11-12	101 Art	S	1:17	0		
111.11-13	101 Art	S	1:17	0		
111.11-14	101 Art	S	1:18	0		
111.11-15	100 Art	S	1:20	0		
111.11-16	100 Art	S	1:21	0		
111.11-17	100 Art	S	1:21	0		
111.11-18	100 Art	S	1:22	0		
111.11-19	110 Health Office	S	1:24	0		
111.11-20	120	S	1:26	0		
111.11-21	MBR	S	1:32	0		
111.11-22	MBR	s	1:32	0		
111.11-23	MBR	S	1:33	0		
111.11-24	Men Faculty	S	1:34	0		
111.11-25	111	S	1:39	0		
111.11-26	111		1:39	0		

**Notes:**

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

Sampled By: 0 [Signature] Print Name Stohl Env: Michael Irwin Date: 10/8/2016

Relinquished By: [Signature] Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider  
 STOHL Job # 2016L-111.11

Client: Niagara Falls CSD Contact: Dave Spacone  
 Building: Niagara Falls High School Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-27	111	S	1:40	HTV8Q_1E		
111.11-28	111	S	1:40	0		
111.11-29	111	S	1:41	0		
111.11-30	111	S	1:42	0		
111.11-31	111	S	1:42	0		
111.11-32	111	S	1:43	0		
111.11-33	111	S	1:43	0		
111.11-34	111	S	1:44	0		
111.11-35	111	S	1:45	0		
111.11-36	CO WBR	DF	1:48	0		
111.11-37	WBR	S	1:49	0		
111.11-38	WBR	S	1:49	0		
111.11-39	Women Faculty	S	1:50	#REF!		
111.11-40	121	S	1:55	#REF!		
111.11-41	121	S	1:56	#REF!		
111.11-42	121	S	1:56	#REF!		
111.11-43	121	S	1:57	#REF!		
111.11-44	121	S	1:57	#REF!		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By: 0 [Signature] Print Name Stohl Env: Michael Irwin Date: 10/8/2016  
 Relinquished By: [Signature] Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016  
 Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8892  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.11

Client: Niagara Falls CSD

Contact: Dave Spacone

Building: Niagara Falls High School

Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-45	121	S	1:58	0		
111.11-46	121	S	1:58	0		
111.11-47	121	S	1:59	0		
111.11-48	121	S	1:59	0		
111.11-49	121	S	2:00	0		
111.11-50	121	S	2:01	0		
111.11-51	Outside 115	HB	1:40	0		
111.11-52	Outside 117	HB	1:41	0		
111.11-53	Outside 116	HB	1:42	0		
111.11-54	Outside 122	HB	1:43	0		
111.11-55	Outside 126	HB	1:44	0		
111.11-56	Outside 127	HB	1:45	0		
111.11-57	Outside 121	HB	1:47	0		
111.11-58	Outside 137	HB	1:48	0		
111.11-59	Outside 136	HB	1:49	0		
111.11-60	Outside Door 8	HB	1:50	0		
111.11-61	Outside 146	HB	1:52	0		
111.11-62	Outside 147	HB	1:53	0		

**Notes:**

Please e-mail lab results to labs@stohlenv.com

Sampled By: Michael Irwin Print Name Michael Irwin Stohl Env: Michael Irwin Date: 10/8/2016

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 10/10/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-8076 ■ (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider  
 STOHL Job # 2016L-111.11

Client: Niagara Falls CSD Contact: Dave Spacone  
 Building: Niagara Falls High School Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-63	Outside Door 6	HB	1:54	0		
111.11-64	Outside Door 2	HB	1:55	0		
111.11-65	Hot Box	WMF	2:20	0		
111.11-66	Hot Box	WMTC	2:24	0		
111.11-200	Training	IM	8:55	0		
111.11-201	Training	S	9:04	0		
111.11-202	Weight RM	DF	9:06	HTV8Q_1E		
111.11-203	256H	S	9:11	0		
111.11-204	256H	S	9:12	0		
111.11-205	256G	S	9:14	0		
111.11-206	256G	S	9:15	0		
111.11-207	256F	S	9:16	0		
111.11-208	256F	S	9:17	0		
111.11-209	256E	S	9:18	0		
111.11-210	256E	S	9:19	0		
111.11-211	256D	S	9:20	0		
111.11-212	256D	S	9:21	0		
111.11-213	256C	S	9:22	0		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By: 0 M J Print Name Stohl Env: Michael Irwin Date: 10/8/2016  
 Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016  
 Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
☎ (716) 312-0070 ☎ (716) 312-8092  
www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.11

Client: Niagara Falls CSD

Contact: Dave Spacone

Building: Niagara Falls High School

Location: 4455 Porter Rd

**LEAD**  
Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-214	256C	S	9:23	0		
111.11-215	255A	S	9:24	0		
111.11-216	255	S	9:25	0		
111.11-217	Staff Lounge	S	9:33	0		
111.11-218	Staff Workroom	S	9:35	0		
111.11-219	CO MBR	DF	9:37	NWCA8FBL_002		
111.11-220	CO MBR	DF	9:38	0		
111.11-221	MBR	S	9:38	0		
111.11-222	MBR	S	9:39	0		
111.11-223	MBR	S	9:40	0		
111.11-224	Men Faculty	S	9:41	0		
111.11-225	211	S	9:45	0		
111.11-226	211	S	9:46	0		
111.11-227	211	S	9:47	0		
111.11-228	211	S	9:48	0		
111.11-229	211	Hood S	9:49	0		
111.11-230	211	S	9:50	0		
111.11-231	211	S	9:51	0		

Notes:  
Please e-mail lab results to labs@stohlenv.com  If checked, also e-mail results to: \_\_\_\_\_

Sampled By: *MI* Print Name Stohl Env: Michael Irwin Date: 10/8/2016

Relinquished By: *E. Henderson Jr.* Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider  
 STOHL Job # 2016L-111.11

Client: Niagara Falls CSD Contact: Dave Spacone  
 Building: Niagara Falls High School Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-232	211	S	9:52	0		
111.11-233	211	S	9:53	0		
111.11-234	211	S	9:54	0		
111.11-235	214 BR	S	9:55	0		
111.11-236	214	S	9:56	0		
111.11-237	WBR	S	9:57	0		
111.11-238	WBR	S	9:58	0		
111.11-239	CO WBR	DF	9:59	NWCA8F_002		
111.11-240	Women Faculty	S	10:00	0		
111.11-241	221	S	10:02	0		
111.11-242	221	S	10:03	0		
111.11-243	221	S	10:04	0		
111.11-244	221	S	10:05	0		
111.11-245	221	S	10:06	0		
111.11-246	221	S	10:07	0		
111.11-247	221	S	10:08	0		
111.11-248	221	S	10:09	0		
111.11-249	221	S	10:09	0		

Notes:  
 Please e-mail lab results to labs@stohienv.com

Sampled By: 0 [Signature] Print Name Stohl Env: Michael Irwin Date: 10/8/2016  
 Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016  
 Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY., BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider  
 STOHL Job # 2016L-111.11

Client: Niagara Falls CSD Contact: Dave Spacone  
 Building: Niagara Falls High School Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-250	221	S	10:10	0		
111.11-251	221	S	10:10	0		
111.11-252	260	S	10:11	0		
111.11-253	260	S	10:11	0		
111.11-254	262	S	10:12	0		
111.11-255	262	S	10:13	0		
111.11-256	264	S	10:14	0		
111.11-257	264	S	10:14	0		
111.11-258	230	S	10:15	0		
111.11-259	WBR	S	10:19	0		
111.11-260	WBR	S	10:19	0		
111.11-261	CO WBR	DF	10:20	NWCA8F_002		
111.11-262	Women Faculty	S	10:21	0		
111.11-263	231	S	10:25	0		
111.11-264	231	S	10:25	0		
111.11-265	231	S	10:26	0		
111.11-266	231	S	10:26	0		
111.11-267	231	S	10:27	0		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By: 0 [Signature] Print Name Stohl Env: Michael Irwin Date: 10/8/2016  
 Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016  
 Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_





# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716)312-0070 (716)312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.11

Client: Niagara Falls CSD

Contact: Dave Spacone

Building: Niagara Falls High School

Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-268	231	S	10:28	0		
111.11-269	231	S	10:28	0		
111.11-270	231	S	10:29	0		
111.11-271	231	S	10:29	0		
111.11-272	231	S	10:30	0		
111.11-273	231	S	10:30	0		
111.11-274	240	S	10:32	0		
111.11-275	MBR	S	10:34	0		
111.11-276	MBR	S	10:34	0		
111.11-277	MBR	S	10:35	0		
111.11-278	CO MBR	DF	10:36	NWCA8F_002		
111.11-279	CO MBR	DF	10:36	0		
111.11-280	Men Faculty	S	10:37	0		
111.11-281	244	S	10:40	0		
111.11-282	WBR	S	10:50	0		
111.11-283	WBR	S	10:50	0		
111.11-284	MBR	S	10:51	0		
111.11-285	MBR	S	10:51	0		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By: 0 [Signature] Print Name Stohl Env: Michael Irwin Date: 10/8/2016

Relinquished By: [Signature] Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-9092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider  
 STOHL Job # 2016L-111.11

Client: Niagara Falls CSD Contact: Dave Spacone  
 Building: Niagara Falls High School Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-300	341	S	9:20	0		
111.11-301	341	S	9:20	0		
111.11-302	341	S	9:20	0		
111.11-303	341	S	9:20	0		
111.11-304	341	S	9:21	0		
111.11-305	341	S	9:21	0		
111.11-306	341	S	9:21	0		
111.11-307	341	S	9:21	0		
111.11-308	341	S	9:22	0		
111.11-309	Hall near 342	DF	9:29	NWCA8FBL-002		
111.11-310	Hall near 342	DF	9:30	NWCA8FBL-002		
111.11-311	Men's bathroom near 342	S	9:31	0		
111.11-312	Men's bathroom near 342	S	9:31	0		
111.11-313	Men's bathroom near 342	S	9:32	0		
111.11-314	Faculty men's near 342	S	9:33	0		
111.11-315	9th gr. Counseling center	S	9:37	0		
111.11-316	Hall near 331	DF	9:40	NWCA8F-002		
111.11-317	Women's near 331	S	9:41	0		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By: 0 [Signature] Print Name Stohl Env: Timothy Thrift Date: 10/8/2016  
 Relinquished By: [Signature] Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016  
 Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.11

Client: Niagara Falls CSD

Contact: Dave Spacone

Building: Niagara Falls High School

Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-318	Women's near 331	S	9:41	0		
111.11-319	Faculty women's near 331	S	9:42	0		
111.11-320	331	S	9:50	0		
111.11-321	331	S	9:51	0		
111.11-322	331	S	9:51	0		
111.11-323	331	S	9:51	0		
111.11-324	331	S	9:52	0		
111.11-325	331	S	9:52	0		
111.11-326	331	S	9:53	0		
111.11-327	331	S	9:53	0		
111.11-328	331	S	9:53	0		
111.11-329	331	S	9:54	0		
111.11-330	331	S	9:54	0		
111.11-331	Hall near 320	DF	10:03	NWCA8FBL-002		
111.11-332	Hall near 320	DF	10:03	NWCA8FBL-002		
111.11-333	Men's bathroom near 320	S	10:04	0		
111.11-334	Men's bathroom near 320	S	10:04	0		
111.11-335	Men's bathroom near 320	S	10:04	0		

Notes:  
 Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: 0 Tim Thrift Print Name Timothy Thrift Date: 10/8/2016

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Date: 10/10/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.11

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Client: Niagara Falls CSD

Contact: Dave Spacone

Building: Niagara Falls High School

Location: 4455 Porter Rd

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-336	Faculty men's near 320	S	10:05	0		
111.11-337	Hall near 320	DF	10:12	NWCA8F-002		
111.11-338	Women's near 320	S	10:12	0		
111.11-339	Women's near 320	S	10:13	0		
111.11-340	Faculty women's near 320	S	10:13	0		
111.11-341	320	S	10:18	0		
111.11-342	320	S	10:19	0		
111.11-343	320	S	10:19	0		
111.11-344	320	S	10:20	0		
111.11-345	320	S	10:21	0		
111.11-346	311	S	10:30	0		
111.11-347	311	S	10:31	0		
111.11-348	311	S	10:32	0		
111.11-349	311	S	10:32	0		
111.11-350	311	S	10:32	0		
111.11-351	311	S	10:33	0		
111.11-352	311	S	10:34	0		
111.11-353	311		10:34	0		

**Notes:**

Please e-mail lab results to labs@stohlenv.com

Sampled By: 0. Tim Thrift Print Name Stöhl Env: Timothy Thrift Date: 10/8/2016

Relinquished By: E. Henderson Jr. Print Name Stöhl Env: Eric Henderson Jr. Date: 10/10/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-0070 ■ (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.11

Client: Niagara Falls CSD

Contact: Dave Spacone

Building: Niagara Falls High School

Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-354	311	S	10:35	0		
111.11-355	321	S	10:45	0		
111.11-356	321	S	10:46	0		
111.11-357	321	S	10:46	0		
111.11-358	321	S	10:47	0		
111.11-359	321	S	10:47	0		
111.11-360	321	S	10:48	0		
111.11-361	321	S	10:48	0		
111.11-362	321	S	10:49	NWCA8F-002		
111.11-363	321	S	10:50	0		
111.11-364	0	0	0:00	0		
111.11-400	Water fountain	DF	7:40	0		
111.11-401	Water fountain	DF	7:40	#REF!		
111.11-402	Room 441	S	7:52	#REF!		
111.11-403	Men's room	S	7:48	#REF!		
111.11-404	Men's room	S	7:48	#REF!		
111.11-405	Men's room	S	7:48	#REF!		
111.11-406	Room 441	S	7:50	#REF!		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By: 0 Tim Thrift Print Name Stohl Env: Timothy Thrift Date: 10/8/2016

Relinquished By: Eric Henderson Jr Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.11

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
4169 ALLENDALE PKWY, BUFFALO, NEW YORK 14219  
☎ (716) 312-0070 ■ (716) 312-8092  
www.stohlenvironmental.com

Client: Niagara Falls CSD

Contact: Dave Spacone

Building: Niagara Falls High School

Location: 4455 Porter Rd

### LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

*Turnaround*

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-407	Room 441	S	7:50	0		
111.11-408	Room 441	S	7:50	0		
111.11-409	Room 441	S	7:50	0		
111.11-410	Room 441	S	7:50	0		
111.11-411	Room 441	S	7:50	0		
111.11-412	Room 441	S	7:50	0		
111.11-413	Room 441	S	7:50	0		
111.11-414	Room 441	S	7:50	0		
<del>111.11-415</del>	<del>Room 441</del>	<del>S</del>	<del>7:50</del>	<del>0</del>		
111.11-416	Room 431	S	8:11	0		
111.11-417	Room 431	S	8:11	0		
111.11-418	Room 431	S	8:11	0		
111.11-419	Room 431	S	8:11	0		
111.11-420	Room 431	S	8:11	0		
111.11-421	Room 431	S	8:11	0		
111.11-422	Room 431	S	8:11	0		
111.11-423	Room 431	S	8:11	0		
111.11-424	Room 431	S	8:11	0		

### Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

Sampled By: 0 Timothy Thrift Print Name Stohl Env: Timothy Thrift Date: 10/8/2016

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

\* 111.11-415 - not submitted



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716)312-0070 (716)312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.11

Client: Niagara Falls CSD

Contact: Dave Spacone

Building: Niagara Falls High School

Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-425	Men's faculty restroom	S	8:14	0		
111.11-426	Women's room	S	8:19	0		
111.11-427	Women's room	S	8:19	0		
111.11-428	Drinking fountain	DF	8:18	0		
111.11-429	Women's faculty restroom	S	8:20	0		
111.11-430	Room 440	S	8:24	0		
111.11-431	Room 440	S	8:24	0		
111.11-432	Room 440	S	8:24	0		
111.11-433	Room 440	S	8:24	0		
111.11-434	Room 440	S	8:24	0		
111.11-435	Room 431	S	8:35	0		
111.11-436	Room 404	S	8:38	0		
111.11-437	Room 404	S	8:38	0		
111.11-438	Room 404	S	8:38	0		
111.11-439	Drinking fountain	DF	8:41	NWCA8F-002		
111.11-440	Women's room	S	8:41	0		
111.11-441	Women's room	S	8:41	0		
111.11-442	Women's faculty restroom	S	8:42	0		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By: 0 Tim Thrift Print Name Stohl Env: Timothy Thrift Date: 10/8/2016

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-0070 ☎ (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.11

Client: Niagara Falls CSD

Contact: Dave Spacone

Building: Niagara Falls High School

Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-443	Drinking fountain	DF	8:43	0		
111.11-444	Drinking fountain	DF	8:43	0		
111.11-445	Men's room	S	8:44	0		
111.11-446	Men's room	S	8:44	0		
111.11-447	Men's room	S	8:44	0		
111.11-448	Men's faculty restroom	S	8:46	0		
111.11-449	Room 420	S	8:49	0		
111.11-450	Room 421	S	8:52	0		
111.11-451	Room 421	S	8:52	0		
111.11-452	Room 421	S	8:52	0		
111.11-453	Room 421	S	8:52	0		
111.11-454	Room 421	S	8:52	0		
111.11-455	Room 421	S	8:52	0		
111.11-456	Room 421	S	8:52	0		
111.11-457	Room 421	S	8:52	0		
111.11-458	Room 421	S	8:52	0		
111.11-459	Room 411	S	9:00	0		
111.11-460	Room 411	S	9:00	0		

**Notes:**

Please e-mail lab results to labs@stohlenv.com  If checked, also e-mail results to: \_\_\_\_\_

Sampled By: Timothy Thrift Print Name Stohl Env: Timothy Thrift Date: 10/8/2016

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_





# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider  
 STOHL Job # 2016L-111.11

Client: Niagara Falls CSD Contact: Dave Spacone  
 Building: Niagara Falls High School Location: 4455 Porter Rd

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-461	Room 411	S	9:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		
0	0	0	0:00	0		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By: 0 Tim Thrift Print Name Stohl Env: Timothy Thrift Date: 10/8/2016  
 Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/10/2016  
 Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) \_\_\_\_\_

STOHL Job # 2016L-111

Client: Niagara Falls CSD

Contact: Dave Spacone


Building: Niagara Falls High School

Location: 4455 Porter Rd., Niagara Falls NY

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
 5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.11-235	214 BR	S	9:55	0		



Notes:  
 Please e-mail lab results to labs@stohlenv.com  If checked, also e-mail results to: \_\_\_\_\_

Sampled By: Mike Irwin Print Name Stohl Env: Mike Irwin Date: 10/8/16  
 Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/26/16  
 Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_