

November 23, 2016

David Spacone  
City School District of the City of Niagara Falls  
Director of Facilities  
630 – 66<sup>th</sup> Street  
Niagara Falls, NY 14304

**Re: Investigation and Sampling of Drinking Water for Lead Concentrations**

Dear Mr. Spacone:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the City School District of the City of Niagara Falls, including:

- Harry F. Abate Elementary School, 1625 Lockport Street, Niagara Falls, New York

This report is prepared to assist the District in complying with the requirements of New York State (NYS) regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on 9/24/2016. The Protocol for the Investigation followed the requirements of NYS regulations as well as United States Environmental Protection Agency (USEPA) Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 18 sources of potable water in Harry F. Abate Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to City School District of the City of Niagara Falls.

Sincerely,  
Stohl Environmental, LLC.



William K. Sisco  
Senior Project Manager

**Investigation and Sampling  
Of Sources of Potable Water  
For Lead Concentrations**

**Prepared for:**

**David Spacone  
City School District of the City of Niagara Falls  
Director of Facilities  
630 – 66<sup>th</sup> Street  
Niagara Falls, NY 14304**

**Prepared by:**



**ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES**

**4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219**

**☎ (716) 312-0070 📠 (716) 312-8092**

**[www.stohlenvironmental.com](http://www.stohlenvironmental.com)**

**Conditions as of September 24, 2016**

## Summary Tabulation

### Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.1 Sampling Protocol and Summary of Results:

Stohl Environmental was retained by City School District of the City of Niagara Falls to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Harry F. Abate Elementary School, 1625 Lockport Street, Niagara Falls, New York

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from all outlets in Harry F. Abate Elementary School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

### Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **‘3Ts for Reducing Lead in Drinking Water in Schools’**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of eight (8) hours, but not more than 18 hours before sample collection.
- **Service Connection Sampling:** Samples were collected at the service connection as follows:
  - **Service Connection Sample:** As detailed in EPA guidance documents, this sample is not a first-draw sample. The cold water tap closest to the service connection was opened, and the sample was collected immediately after a change in water temperature was detected, or after 30 seconds.
  - **Water Main Sample:** This sample was collected at the same location as the Service Connection sample; however, it was collected after water was allowed to run an additional three (3) minutes after the temperature change, but not more than three (3) minutes and thirty (30) seconds.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.2 Executive Summary of Sampling and Analysis:

### Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Harry F. Abate Elementary School	9/24/2016	158	140	18	0	0

\*\* Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

### Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples and Confirmatory Samples				
Sample #	Sample Type	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
111.4-7	First Draw	Room 105	Sink	15.5
111.4-13	First Draw	Room 110	Sink	38.6
111.4-22	First Draw	Room 122	Sink	65.4
111.4-25	First Draw	Room 124-D	Sink	47.3
111.4-59	First Draw	Room 158	Sink	36.8
111.4-61	First Draw	Room 157	Sink	271
111.4-62	First Draw	Room 157	Bubbler	95.4
111.4-63	First Draw	Room 163	Bubbler	18.1
111.4-72	First Draw	Room 175/176	Sink	75.7
111.4-92	First Draw	Room 248	Sink	23.5
111.4-107	First Draw	Room 202 Bathroom (south end of room)	Sink	53.0
111.4-108	First Draw	Room 202 Bathroom (north end of room)	Sink	15.9
111.4-148	First Draw	Exterior East Courtyard	Hose Bib	20.2
111.4-151	First Draw	Exterior South Wall	Hose Bib	41.6
111.4-152	First Draw	Exterior Door 1 East	Hose Bib	196
111.4-153	First Draw	Exterior Door 1 West	Hose Bib	393
111.4-154	First Draw	Exterior Northwest Wall	Hose Bib	277
111.4-157	First Draw	Exterior South Wall	Hose Bib	67.0

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

### **1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:**

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than one (1) business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than ten (10) business days after the school received the laboratory report.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.4 Laboratory Analytical Reports by Building



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186514

Matrix: Drinking Water
Received: 09/29/16
Reported: 11/22/16

Attn:
Project: Harry F. Abate Elem.
Location: 1625 Lockport St Niagara Falls
Number: 2016L-111.4

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 186514-001 through 186514-011, all for Lead analysis.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.





Customer: Stohl Environmental, LLC (4507)  
Address: 4169 Allendale Parkway  
Blasdell, NY 14219

Order #: 186514

Matrix: Drinking Water  
Received: 09/29/16  
Reported: 11/22/16

Attn:  
Project: Harry F. Abate Elem.  
Location: 1625 Lockport St Niagara Falls  
Number: 2016L-111.4

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
186514-012	111.4-12	107 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/17/16	SA
186514-013	111.4-13	110 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	38.6	10.0	µg/L	11/17/16	SA
186514-014	111.4-14	112 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/17/16	SA
186514-015	111.4-15	112 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/17/16	SA
186514-016	111.4-16	114 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/17/16	SA
186514-017	111.4-17	114 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/17/16	SA
186514-018	111.4-18	115 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/17/16	SA
186514-019	111.4-19	115 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/17/16	SA
186514-020	111.4-20	116 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/17/16	SA
186514-021	111.4-21	116 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/17/16	SA
186514-022	111.4-22	122 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	65.4	25.0	µg/L	11/17/16	SA

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186514

Matrix: Drinking Water
Received: 09/29/16
Reported: 11/22/16

Attn:
Project: Harry F. Abate Elem.
Location: 1625 Lockport St Niagara Falls
Number: 2016L-111.4

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 186514-023 through 186514-033, all showing Lead analysis results.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186514

Matrix: Drinking Water
Received: 09/29/16
Reported: 11/22/16

Attn:
Project: Harry F. Abate Elem.
Location: 1625 Lockport St Niagara Falls
Number: 2016L-111.4

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 16 rows of lead analysis data for samples 186514-034 through 186514-044.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186514

Matrix: Drinking Water
Received: 09/29/16
Reported: 11/22/16

Attn:
Project: Harry F. Abate Elem.
Location: 1625 Lockport St Niagara Falls
Number: 2016L-111.4

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 186514-045 through 186514-055, all for Lead analysis with results mostly <5.00.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Stohl Environmental, LLC (4507)  
Address: 4169 Allendale Parkway  
Blasdell, NY 14219

Order #: 186514

Matrix: Drinking Water  
Received: 09/29/16  
Reported: 11/22/16

Attn:  
Project: Harry F. Abate Elem.  
Location: 1625 Lockport St Niagara Falls  
Number: 2016L-111.4

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
186514-056	111.4-56	154 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/17/16	SA
186514-057	111.4-57	155 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/17/16	SA
186514-058	111.4-58	155 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/17/16	SA
186514-059	111.4-59	158 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	36.8	5.00	µg/L	11/17/16	SA
186514-060	111.4-60	158 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	7.15	5.00	µg/L	11/17/16	SA
186514-061	111.4-61	157 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	271	50.0	µg/L	11/17/16	SA
186514-062	111.4-62	157 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	95.4	50.0	µg/L	11/17/16	SA
186514-063	111.4-63	163 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	18.1	5.00	µg/L	11/17/16	SA
186514-064	111.4-64	156 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/17/16	SA
186514-065	111.4-65	156 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/17/16	SA
186514-066	111.4-66	168 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/17/16	SA

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186514

Matrix: Drinking Water
Received: 09/29/16
Reported: 11/22/16

Attn:
Project: Harry F. Abate Elem.
Location: 1625 Lockport St Niagara Falls
Number: 2016L-111.4

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 186514-067 through 186514-077, all for Lead analysis.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Stohl Environmental, LLC (4507)  
Address: 4169 Allendale Parkway  
Blasdell, NY 14219

Order #: 186514

Matrix: Drinking Water  
Received: 09/29/16  
Reported: 11/22/16

Attn:  
Project: Harry F. Abate Elem.  
Location: 1625 Lockport St Niagara Falls  
Number: 2016L-111.4

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
186514-078	111.4-78	240 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	SA
186514-079	111.4-79	240 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	SA
186514-080	111.4-80	241 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	SA
186514-081	111.4-81	241 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	SA
186514-082	111.4-82	242 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	SA
186514-083	111.4-83	242 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	SA
186514-084	111.4-84	243 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	SA
186514-085	111.4-85	243 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	SA
186514-086	111.4-86	244 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	SA
186514-087	111.4-87	244 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	SA
186514-088	111.4-88	245 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	11.2	5.00	µg/L	11/18/16	SA

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

# Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117  
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

**Customer:** Stohl Environmental, LLC (4507)  
**Address:** 4169 Allendale Parkway  
Blasdell, NY 14219

<b>Order #:</b>	186514
-----------------	--------

**Matrix** Drinking Water  
**Received** 09/29/16  
**Reported** 11/22/16

**Attn:**  
**Project:** Harry F. Abate Elem.  
**Location:** 1625 Lockport St Niagara Falls  
**Number:** 2016L-111.4

**PO Number:**

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
186514-089	111.4-89	245 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	8.57	5.00	µg/L	11/18/16	SA
186514-090	111.4-90	247 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	SA
186514-091	111.4-91	247 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH
186514-092	111.4-92	248 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	23.5	5.00	µg/L	11/18/16	MH
186514-093	111.4-93	248 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH
186514-094	111.4-94	249 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH
186514-095	111.4-95	249 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH
186514-096	111.4-96	250 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH
186514-097	111.4-97	250 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH
186514-098	111.4-98	251 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH
186514-099	111.4-99	251 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.





Analysis Report

# Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117  
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

**Customer:** Stohl Environmental, LLC (4507)  
**Address:** 4169 Allendale Parkway  
Blasdell, NY 14219

**Order #:** 186514

**Matrix** Drinking Water  
**Received** 09/29/16  
**Reported** 11/22/16

**Attn:**

**Project:** Harry F. Abate Elem.  
**Location:** 1625 Lockport St Niagara Falls  
**Number:** 2016L-111.4

**PO Number:**

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
186514-100	111.4-100	252 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH
186514-101	111.4-101	252 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH
186514-102	111.4-102	254 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH
186514-103	111.4-103	254 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH
186514-104	111.4-104	254 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH
186514-105	111.4-105	A-Wing Hallway DF					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH
186514-106	111.4-106	202 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH
186514-107	111.4-107	202 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	53.0	25.0	µg/L	11/18/16	MH
186514-108	111.4-108	202 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	15.9	5.00	µg/L	11/18/16	MH
186514-109	111.4-109	204 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	5.26	5.00	µg/L	11/18/16	MH
186514-110	111.4-110	204 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/18/16	MH

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186514

Matrix: Drinking Water
Received: 09/29/16
Reported: 11/22/16

Attn:
Project: Harry F. Abate Elem.
Location: 1625 Lockport St Niagara Falls
Number: 2016L-111.4

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 18 rows of data for Lead analysis across various sample IDs (186514-111 to 186514-121).

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186514

Matrix: Drinking Water
Received: 09/29/16
Reported: 11/22/16

Attn:
Project: Harry F. Abate Elem.
Location: 1625 Lockport St Niagara Falls
Number: 2016L-111.4

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 15 rows of lead analysis data for samples 186514-122 through 186514-132.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186514

Matrix: Drinking Water
Received: 09/29/16
Reported: 11/22/16

Attn:
Project: Harry F. Abate Elem.
Location: 1625 Lockport St Niagara Falls
Number: 2016L-111.4

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include various sample IDs (186514-133 to 186514-143) and their corresponding analysis results for Lead.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186514

Matrix: Drinking Water
Received: 09/29/16
Reported: 11/22/16

Attn:
Project: Harry F. Abate Elem.
Location: 1625 Lockport St Niagara Falls
Number: 2016L-111.4

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include various sample IDs (186514-144 to 186514-154) and their corresponding analysis results for Lead.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186514

Matrix: Drinking Water
Received: 09/29/16
Reported: 11/22/16

Attn:
Project: Harry F. Abate Elem.
Location: 1625 Lockport St Niagara Falls
Number: 2016L-111.4

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include Metals Analysis for Lead at various locations (HB N Playground HB, HB W Wall HB, HB S Wall HB, Pool) with results like <5.00 and 67.0.

186514-11/22/16 03:59 PM

EPA Regulatory Limits

Table with columns: Parameter, Reg. Limit, Unit. Row: Lead, 15.0, µg/L

Abisola O Kasali
Reviewed By: Abisola Kasali
Metals Supervisor

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186514

Matrix: Drinking Water
Received: 09/29/16
Reported: 11/22/16

Attn:
Project: Harry F. Abate Elem.
Location: 1625 Lockport St Niagara Falls
Number: 2016L-111.4

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst

Certifications

Table with 11 columns: Parameter, Method, Matrix, CA, CT, FL, NJ, NY, RI, VA

Key

Table with 3 columns: State, Regulatory Agency - Lab ID, Certificate Number

'X' indicates that the analyte is accredited.

If your state is not listed above, call laboratory for accreditation/certification information.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider  
 STOHL Job # 2016L-111.4

Client: Niagar Falls CSD Contact: Dave Spacone  
 Building: Harry F. Abate Elem. Location: 1625 Lockport St., Niagara Falls NY

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X Turnaround 5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-1	A wing	DF	8:20	HALSEY TAYLOR		
111.4-2	102	S	8:22	0		
111.4-3	102	S	8:24	0		
111.4-4	102	S	8:26	0		
111.4-5	104	S	8:28	0		
111.4-6	104	B	8:30	0		
111.4-7	105	S	8:32	0		
111.4-8	105	B	8:34	0		
111.4-9	106	S	8:36	0		
111.4-10	106	B	8:38	0		
111.4-11	107	S	8:40	0		
111.4-12	107	B	8:42	0		
111.4-13	110	S	8:44	0		
111.4-14	112	S	8:46	0		
111.4-15	112	B	8:48	0		
111.4-16	114	S	8:50	0		
111.4-17	114	B	8:52	0		
111.4-18	115	S	8:54	0		

186514 S 158  
  
 V:\186\186514  
 fghraizi 9/29/2016 2:4 5:00 PM  
 Federal Express 78420 J410931

Notes:  
 Please e-mail lab results to labs@stohlenv.com  If checked, also e-mail results to: \_\_\_\_\_

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 9/24/2016  
 Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 9/27/2016  
 Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_





# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.4

Client: Niagar Falls CSD

Contact: Dave Spacone

Building: Harry F. Abate Elem.

Location: 1625 Lockport St., Niagara Falls NY

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-19	115	B	8:56	0		
111.4-20	116	S	8:58	0		
111.4-21	116	B	9:00	0		
111.4-22	122	S	9:02	0		
111.4-23	123	S	9:04	0		
111.4-24	123	S	9:06	0		
111.4-25	124-D	S	9:08	0		
111.4-26	131	B	9:10	0		
111.4-27	B Wing	DF	9:12	HALSEY TAYLOR		
111.4-28	133	S	9:14	0		
111.4-29	134	S	9:16	0		
111.4-30	135	S	9:18	0		
111.4-31	136	S	9:20	0		
111.4-32	138	S	9:22	0		
111.4-33	138	S	9:24	0		
111.4-34	138	S	9:26	0		
111.4-35	138	S	9:28	0		
111.4-36	138	S	9:30	0		

Notes:  
 Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 9/24/2016

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.4

Client: Niagar Falls CSD

Contact: Dave Spacone

Building: Harry F. Abate Elem.

Location: 1625 Lockport St., Niagara Falls NY

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

*Turnaround*  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-37	143	S	9:32	0		
111.4-38	145	S	9:34	0		
111.4-39	145	B	9:36	0		
111.4-40	146	S	9:38	0		
111.4-41	146	B	9:40	0		
111.4-42	147	S	9:42	0		
111.4-43	147	B	9:44	0		
111.4-44	148	S	9:46	0		
111.4-45	148	B	9:48	0		
111.4-46	149	S	9:50	0		
111.4-47	149	B	9:52	0		
111.4-48	150	S	9:54	0		
111.4-49	150	B	9:56	0		
111.4-50	151 W. Rest.	S	9:58	0		
111.4-51	151 M. Rest.	S	10:00	0		
111.4-52	151	S	10:02	0		
111.4-53	153	S	10:04	0		
111.4-54	153	B	10:06	0		

Notes:  
 Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/24/2016

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
(716) 312-0070 (716) 312-8092  
www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.4

Client: Niagar Falls CSD

Contact: Dave Spacone

Building: Harry F. Abate Elem.

Location: 1625 Lockport St., Niagara Falls NY

**LEAD**  
Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-55	154	S	10:08	0		
111.4-56	154	B	10:10	0		
111.4-57	155	S	10:12	0		
111.4-58	155	B	10:14	0		
111.4-59	158	S	10:16	0		
111.4-60	158	B	10:18	0		
111.4-61	157	S	10:20	0		
111.4-62	157	B	10:22	0		
111.4-63	163	B	10:24	0		
111.4-64	156	S	10:26	0		
111.4-65	156	B	10:28	0		
111.4-66	168	S	10:30	0		
111.4-67	Gym Hallway	DF	10:32	HALSEY TAYLOR		
111.4-68	170	S	10:34	0		
111.4-69	171	S	10:36	0		
111.4-70	174	S	10:38	0		
111.4-71	174	DF	10:40	HALSEY TAYLOR		
111.4-72	175/176	S	10:42	0		

Notes:  
Please e-mail lab results to labs@stohlenv.com

Sampled By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/24/2016

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-0070 ■ (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider  
 STOHL Job # 2016L-111.4

Client: Niagar Falls CSD Contact: Dave Spacone  
 Building: Harry F. Abate Elem. Location: 1625 Lockport St., Niagara Falls NY

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-73	2nd Fl. C-wing	DF	10:44	HALSEY TAYLOR		
111.4-74	238	S	10:46	0		
111.4-75	238	B	10:48	0		
111.4-76	239	S	10:50	0		
111.4-77	239	B	10:52	0		
111.4-78	240	S	10:54	0		
111.4-79	240	B	10:56	0		
111.4-80	241	S	10:58	0		
111.4-81	241	B	11:00	0		
111.4-82	242	S	11:02	0		
111.4-83	242	B	11:04	0		
111.4-84	243	S	11:06	0		
111.4-85	243	B	11:08	0		
111.4-86	244	S	11:10	0		
111.4-87	244	B	11:12	0		
111.4-88	245	S	11:14	0		
111.4-89	245	B	11:16	0		
111.4-90	247	S	11:18	0		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/24/2016  
 Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/27/2016  
 Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-0070 ■ (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.4

Client: Niagar Falls CSD

Contact: Dave Spacone

Building: Harry F. Abate Elem.

Location: 1625 Lockport St., Niagara Falls NY

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-91	247	B	11:20	0		
111.4-92	248	S	11:22	0		
111.4-93	248	B	11:24	0		
111.4-94	249	S	11:26	0		
111.4-95	249	B	11:28	0		
111.4-96	250	S	11:30	0		
111.4-97	250	B	11:32	0		
111.4-98	251	S	11:34	0		
111.4-99	251	B	11:36	0		
111.4-100	252	S	11:38	0		
111.4-101	252	B	11:40	0		
111.4-102	254	S	11:42	0		
111.4-103	254	S	11:44	0		
111.4-104	254	S	11:46	0		
111.4-105	A-wing Hallway	DF	11:48	0		
111.4-106	202	S	11:50	0		
111.4-107	202	S	11:52	0		
111.4-108	202	S	11:54	0		

Notes:  
 Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 9/24/2016

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
(716) 312-0070 (716) 312-8092  
www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.4

Client: Niagar Falls CSD

Contact: Dave Spacone

Building: Harry F. Abate Elem.

Location: 1625 Lockport St., Niagara Falls NY

**LEAD**  
Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-109	204	S	11:56	0		
111.4-110	204	B	11:58	0		
111.4-111	205	S	12:00	0		
111.4-112	205	B	12:02	0		
111.4-113	206	S	12:04	0		
111.4-114	206	B	12:06	0		
111.4-115	207	S	12:08	0		
111.4-116	207	B	12:10	0		
111.4-117	208	S	12:12	0		
111.4-118	208	B	12:14	0		
111.4-119	209	S	12:16	0		
111.4-120	209	B	12:18	0		
111.4-121	212	S	12:20	0		
111.4-122	212	B	12:22	0		
111.4-123	213	S	12:24	0		
111.4-124	213	B	12:26	0		
111.4-125	214	S	12:28	0		
111.4-126	214	B	12:30	0		

Notes:  
Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/24/2016

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.4

Client: Niagar Falls CSD

Contact: Dave Spacone

Building: Harry F. Abate Elem.

Location: 1625 Lockport St., Niagara Falls NY

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-127	215	S	12:32	0		
111.4-128	215	B	12:34	0		
111.4-129	216	S	12:36	0		
111.4-130	216	B	12:38	0		
111.4-131	217	S	12:40	0		
111.4-132	217	B	12:42	0		
111.4-133	219	S	12:44	0		
111.4-134	219	S	12:46	0		
111.4-135	226	S	12:48	0		
111.4-136	226	B	12:50	0		
111.4-137	227	S	12:52	0		
111.4-138	227	B	12:54	0		
111.4-139	230	S	12:56	0		
111.4-140	230 mens	S	12:58	0		
111.4-141	230 womens	S	13:00	0		
111.4-142	232	S	13:02	0		
111.4-143	232	S	13:04	0		
111.4-144	233	S	13:06	0		

Notes:  
 Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/24/2016

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.4

Client: Niagar Falls CSD

Contact: Dave Spacone

Building: Harry F. Abate Elem.

Location: 1625 Lockport St., Niagara Falls NY

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-145	237	S	13:08	0		
111.4-146	WMF BASEMENT	WMF	13:10	0		
111.4-147	WMTC BASEMENT	WMTC	13:20	0		
111.4-148	HB E. COURTYARD	HB	13:27	0		
111.4-149	HB W. COURTYARD	HB	13:30	0		
111.4-150	HB E. COURTYARD	HB	13:32	0		
111.4-151	HB S. WALL	HB	13:34	0		
111.4-152	HB DOOR 1 E.	HB	13:36	0		
111.4-153	HB DOOR 1 W.	HB	13:38	0		
111.4-154	HB N.W. WALL	HB	13:40	0		
111.4-155	HB N. PLAYGROUND	HB	13:42	0		
111.4-156	HB W. WALL	HB	13:44	0		
111.4-157	HB S. WALL	HB	13:46	0		
111.4-158	POOL	POOL	13:50	0		
				0		
				0		
				0		
				0		
				0		

Notes:  
 Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

Sampled By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/24/2016

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_





ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued September 22, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2003) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

**Metals I**

Lead, Total

EPA 200.9 Rev. 2.2



Serial No.: 55043

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2003) for the category  
ENVIRONMENTAL ANALYSES NON POTABLE WATER  
All approved analytes are listed below:*

**Metals I**

Lead, Total  
EPA 200.7 Rev. 4.4  
EPA 6010C  
EPA 7000B  
EPA 200.9 Rev. 2.2

**Sample Preparation Methods**

EPA 3010A  
EPA 3005A  
EPA 3020A

NEW  
YORK  
STATE

Department  
of Health

Serial No.: 54667

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2003) for the category  
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE  
All approved analytes are listed below:*

**Characteristic Testing**

TCLP EPA 1311

**Polychlorinated Biphenyls**

PCB-1268 EPA 8082A

**Metals I**

**Sample Preparation Methods**

Barium, Total EPA 6010C

EPA 3010A

Cadmium, Total EPA 6010C

EPA 3050B

Chromium, Total EPA 6010C

EPA 3550C

Lead, Total EPA 6010C

EPA 3031

EPA 7000B

Nickel, Total EPA 6010C

Silver, Total EPA 6010C

**Metals II**

Antimony, Total EPA 6010C

Arsenic, Total EPA 6010C

Chromium VI EPA 7196A

Mercury, Total EPA 7471B

Selenium, Total EPA 6010C

**Polychlorinated Biphenyls**

PCB-1016 EPA 8082A

PCB-1221 EPA 8082A

PCB-1232 EPA 8082A

PCB-1242 EPA 8082A

PCB-1248 EPA 8082A

PCB-1254 EPA 8082A

PCB-1260 EPA 8082A

PCB-1262 EPA 8082A

NEW  
YORK  
STATE

Department  
of Health

Serial No.: 54668

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory for the category  
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE  
All approved subcategories and/or analytes are listed below:*

**Miscellaneous**

Asbestos in Friable Material	EPA 600/M4/82/020
Asbestos in Non-Friable Material-PLM	Item 198.6 of Manual (NOB by PLM)
Lead in Dust Wipes	EPA 7000B
Lead in Paint	EPA 7000B

**Sample Preparation Methods**

EPA 3050B



**Serial No.: 54669**

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory for the category  
ENVIRONMENTAL ANALYSES AIR AND EMISSIONS  
All approved subcategories and/or analytes are listed below:*

**Metals I**

Lead, Total NIOSH 7082  
40 CFR PART 50 1984 APP G

**Miscellaneous**

Fibers NIOSH 7400 A RULES



Department  
of Health

Serial No.: 54670

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.6 Chains of Custody



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-0070 ■ (716) 312-8092  
 www.stohlenvironmental.com

STOHL Job # 2016L-111.4

Client: Niagar Falls CSD Contact: Dave Spacone

Building: Harry F. Abate Elem. Location: 1625 Lockport St., Niagara Falls NY

<b>LEAD</b>	
Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 <u>X</u>	Turnaround <u>5 Days</u>

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-1	A wing	DF	8:20	HALSEY TAYLOR		
111.4-2	102	S	8:22	0		
111.4-3	102	S	8:24	0		
111.4-4	102	S	8:26	0		
111.4-5	104	S	8:28	0		
111.4-6	104	B	8:30	0		
111.4-7	105	S	8:32	0		
111.4-8	105	B	8:34	0		
111.4-9	106	S	8:36	0		
111.4-10	106	B	8:38	0		
111.4-11	107	S	8:40	0		
111.4-12	107	B	8:42	0		
111.4-13	110	S	8:44	0		
111.4-14	112	S	8:46	0		
111.4-15	112	B	8:48	0		
111.4-16	114	S	8:50	0		
111.4-17	114	B	8:52	0		
111.4-18	115	S	8:54	0		

Notes:  
 Please e-mail lab results to labs@stohlenv.com  If checked, also e-mail results to: \_\_\_\_\_

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 9/24/2016

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_





# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

STOHL Job # 2016L-111.4

Client: Niagar Falls CSD

Contact: Dave Spacone

Building: Harry F. Abate Elem.

Location: 1625 Lockport St., Niagara Falls NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-19	115	B	8:56	0		
111.4-20	116	S	8:58	0		
111.4-21	116	B	9:00	0		
111.4-22	122	S	9:02	0		
111.4-23	123	S	9:04	0		
111.4-24	123	S	9:06	0		
111.4-25	124-D	S	9:08	0		
111.4-26	131	B	9:10	0		
111.4-27	B Wing	DF	9:12	HALSEY TAYLOR		
111.4-28	133	S	9:14	0		
111.4-29	134	S	9:16	0		
111.4-30	135	S	9:18	0		
111.4-31	136	S	9:20	0		
111.4-32	138	S	9:22	0		
111.4-33	138	S	9:24	0		
111.4-34	138	S	9:26	0		
111.4-35	138	S	9:28	0		
111.4-36	138	S	9:30	0		

Notes:

Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/24/2016

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

STOHL Job # 2016L-111.4

Client: Niagar Falls CSD

Contact: Dave Spacone

Building: Harry F. Abate Elem.

Location: 1625 Lockport St., Niagara Falls NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-37	143	S	9:32	0		
111.4-38	145	S	9:34	0		
111.4-39	145	B	9:36	0		
111.4-40	146	S	9:38	0		
111.4-41	146	B	9:40	0		
111.4-42	147	S	9:42	0		
111.4-43	147	B	9:44	0		
111.4-44	148	S	9:46	0		
111.4-45	148	B	9:48	0		
111.4-46	149	S	9:50	0		
111.4-47	149	B	9:52	0		
111.4-48	150	S	9:54	0		
111.4-49	150	B	9:56	0		
111.4-50	151 W. Rest.	S	9:58	0		
111.4-51	151 M. Rest.	S	10:00	0		
111.4-52	151	S	10:02	0		
111.4-53	153	S	10:04	0		
111.4-54	153	B	10:06	0		

Notes:

Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/24/2016

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-111.4

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Client: Niagar Falls CSD

Contact: Dave Spacone

Building: Harry F. Abate Elem.

Location: 1625 Lockport St., Niagara Falls NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-55	154	S	10:08	0		
111.4-56	154	B	10:10	0		
111.4-57	155	S	10:12	0		
111.4-58	155	B	10:14	0		
111.4-59	158	S	10:16	0		
111.4-60	158	B	10:18	0		
111.4-61	157	S	10:20	0		
111.4-62	157	B	10:22	0		
111.4-63	163	B	10:24	0		
111.4-64	156	S	10:26	0		
111.4-65	156	B	10:28	0		
111.4-66	168	S	10:30	0		
111.4-67	Gym Hallway	DF	10:32	HALSEY TAYLOR		
111.4-68	170	S	10:34	0		
111.4-69	171	S	10:36	0		
111.4-70	174	S	10:38	0		
111.4-71	174	DF	10:40	HALSEY TAYLOR		
111.4-72	175/176	S	10:42	0		

Notes:

Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/24/2016

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

STOHL Job # 2016L-111.4

Client: Niagar Falls CSD

Contact: Dave Spacone

Building: Harry F. Abate Elem.

Location: 1625 Lockport St., Niagara Falls NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-73	2nd Fl. C-wing	DF	10:44	HALSEY TAYLOR		
111.4-74	238	S	10:46	0		
111.4-75	238	B	10:48	0		
111.4-76	239	S	10:50	0		
111.4-77	239	B	10:52	0		
111.4-78	240	S	10:54	0		
111.4-79	240	B	10:56	0		
111.4-80	241	S	10:58	0		
111.4-81	241	B	11:00	0		
111.4-82	242	S	11:02	0		
111.4-83	242	B	11:04	0		
111.4-84	243	S	11:06	0		
111.4-85	243	B	11:08	0		
111.4-86	244	S	11:10	0		
111.4-87	244	B	11:12	0		
111.4-88	245	S	11:14	0		
111.4-89	245	B	11:16	0		
111.4-90	247	S	11:18	0		

**Notes:**

Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/24/2016

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
(716) 312-0070 (716) 312-8092  
www.stohlenvironmental.com

STOHL Job # 2016L-111.4

Client: Niagar Falls CSD

Contact: Dave Spacone

Building: Harry F. Abate Elem.

Location: 1625 Lockport St., Niagara Falls NY

**LEAD**  
Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-91	247	B	11:20	0		
111.4-92	248	S	11:22	0		
111.4-93	248	B	11:24	0		
111.4-94	249	S	11:26	0		
111.4-95	249	B	11:28	0		
111.4-96	250	S	11:30	0		
111.4-97	250	B	11:32	0		
111.4-98	251	S	11:34	0		
111.4-99	251	B	11:36	0		
111.4-100	252	S	11:38	0		
111.4-101	252	B	11:40	0		
111.4-102	254	S	11:42	0		
111.4-103	254	S	11:44	0		
111.4-104	254	S	11:46	0		
111.4-105	A-wing Hallway	DF	11:48	0		
111.4-106	202	S	11:50	0		
111.4-107	202	S	11:52	0		
111.4-108	202	S	11:54	0		

Notes:  
Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/24/2016

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

STOHL Job # 2016L-111.4

Client: Niagar Falls CSD

Contact: Dave Spacone

Building: Harry F. Abate Elem.

Location: 1625 Lockport St., Niagara Falls NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-109	204	S	11:56	0		
111.4-110	204	B	11:58	0		
111.4-111	205	S	12:00	0		
111.4-112	205	B	12:02	0		
111.4-113	206	S	12:04	0		
111.4-114	206	B	12:06	0		
111.4-115	207	S	12:08	0		
111.4-116	207	B	12:10	0		
111.4-117	208	S	12:12	0		
111.4-118	208	B	12:14	0		
111.4-119	209	S	12:16	0		
111.4-120	209	B	12:18	0		
111.4-121	212	S	12:20	0		
111.4-122	212	B	12:22	0		
111.4-123	213	S	12:24	0		
111.4-124	213	B	12:26	0		
111.4-125	214	S	12:28	0		
111.4-126	214	B	12:30	0		

Notes:

Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/24/2016

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

STOHL Job # 2016L-111.4

Client: Niagar Falls CSD

Contact: Dave Spacone

Building: Harry F. Abate Elem.

Location: 1625 Lockport St., Niagara Falls NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-127	215	S	12:32	0		
111.4-128	215	B	12:34	0		
111.4-129	216	S	12:36	0		
111.4-130	216	B	12:38	0		
111.4-131	217	S	12:40	0		
111.4-132	217	B	12:42	0		
111.4-133	219	S	12:44	0		
111.4-134	219	S	12:46	0		
111.4-135	226	S	12:48	0		
111.4-136	226	B	12:50	0		
111.4-137	227	S	12:52	0		
111.4-138	227	B	12:54	0		
111.4-139	230	S	12:56	0		
111.4-140	230 mens	S	12:58	0		
111.4-141	230 womens	S	13:00	0		
111.4-142	232	S	13:02	0		
111.4-143	232	S	13:04	0		
111.4-144	233	S	13:06	0		

Notes:

Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/24/2016

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

STOHL Job # 2016L-111.4

Client: Niagar Falls CSD

Contact: Dave Spacone

Building: Harry F. Abate Elem.

Location: 1625 Lockport St., Niagara Falls NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.4-145	237	S	13:08	0		
111.4-146	WMF BASEMENT	WMF	13:10	0		
111.4-147	WMTC BASEMENT	WMTC	13:20	0		
111.4-148	HB E. COURTYARD	HB	13:27	0		
111.4-149	HB W. COURTYARD	HB	13:30	0		
111.4-150	HB E. COURTYARD	HB	13:32	0		
111.4-151	HB S. WALL	HB	13:34	0		
111.4-152	HB DOOR 1 E.	HB	13:36	0		
111.4-153	HB DOOR 1 W.	HB	13:38	0		
111.4-154	HB N.W. WALL	HB	13:40	0		
111.4-155	HB N. PLAYGROUND	HB	13:42	0		
111.4-156	HB W. WALL	HB	13:44	0		
111.4-157	HB S. WALL	HB	13:46	0		
111.4-158	POOL	POOL	13:50	0		
				0		
				0		
				0		
				0		

Notes:

Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/24/2016

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_